



SMAP FIRE & SAFETY

Sales Services



☎ smapfireandsafety@gmail.com Mob. ☎ 7972118912 ☎ 9422996824

Head Office - H.No.5-6-70, Keshav - Vandana Niwas, Narali Bagh Near, Tridal Apartment, Chhatrapati Sambhajanagar (M.S.)

Date: - 17.06.2025

CERTIFICATE

Certified that /We have carried out inspection and life safety measures installed the building or premises namely.

HAP INTERNATIONAL SCHOOL

Chikalthana Chhatrapati Sambhajanagar {Aurangabad}

I/We further certify that these installations in above mentioned building are maintained in good repair and efficient conditions during the period **Refilling Date:- 16.06.2025 Next Refilling Date:-15.06.2026 HPT Date:- 2025 Next HPT Date:- 2030** as required under the provision of the Maharashtra Fire prevention and life safety Measures Act.2006 (Mah. 11 of 2007). The details of the inspection of installation carried out by me /us mentioned in the report appended here with.

DETAILS OF EXTINGUISHER'S

Sr. No	Type of Fire Extinguisher	CAP	Total	Refilling Date	Next Refilling Date
1	ABC	06 KG	14 Nos	16.06.2025	15.06.2026
2	ABC	04 KG	03 Nos	16.06.2025	15.06.2026
3	ABC	02 KG	12 Nos	16.06.2025	15.06.2026
4	CO2	4.5 KG	01 Nos	16.06.2025	15.06.2026

Place: - Chhatrapati Sambhajanagar

SMAP Fire And Safety Sales Services

Date: - 17.06.2025


Proprietor

Signature and address of the licensed agency

Licensed No : 105129371803/2018

Govt.of Maharashtra No.887 Certificate

ISO Certification Number-305024011255Q

